

# Compliance Statement

No. 2023-519

## Connecting Hardware, Category 5e

### Company

Qubix S.p.A.  
Via Canada 22/A  
35127 Padova  
Italy

### Product description

Unscreened and Screened Category 5e RJ45 Wall Outlet characterised up to 100 MHz, 100  $\Omega$

### Product identification

QUBIX2001013 / CCS 2001013  
QUBIX2001014 / CCS 2001014

### Generic cabling and cabling components standards - Category 5e connector requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 60603-7-2:2010 (Ed. 2.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

### Technical report

12330921-01, DANAK-19/23656

### EC Cabling product ID

5010

### CS valid until

1 September 2024

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 9 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 28 August 2023

  
Lars Lindskov Pedersen  
Test Manager

  
Dennis Andersen  
Head of Department

